



UPVC PIPE SHALL BE PROTECTED WITH 6mm THICKNESS OF DENSO TAPE OR EQUIVILANT WHERE IT PASSES THROUGH THE WATER STOP

1. WATER STOPS SHALL BE CONSTRUCTED IN THE TRENCH WHERE SHOWN ON THE PLAN OR WHERE ORDERED BY THE ENGINEER.
2. WATER STOPS MAY BE MODIFIED AT THE ENGINEERS DIRECTION AS CONDITIONS REQUIRE.

SCALE NTS	 <p>THAMES COROMANDEL DISTRICT COUNCIL</p>	SHEET TITLE WATER STOPS	PLAN NO. 6000 SHEET 21
			DATE ISSUED 14 JAN 2000
			ISSUE A
			SHEET NO. 1 of 1